


PROFORMA REGARDING SAFE DRINKING WATER  
CERTIFICATE

NO.....

DATE.....04/02/2022

it is certified that an inspection team headed by Mr. C. S. Sonwani..... sub Engineer (name of officers with designation) From sub Engineer from PHE (name of department/ office) Inspected the DAV MUKHYAMANTRI PUBLIC SCHOOL, Vishrampuri BLOCK- Baderajpur (494347) ( name and address of the school ) on 02/02/2022 and found the DAV MUKHYAMANTRI PUBLIC SCHOOL, Vishrampuri Block- Baderajpur, District- Kondagaon (name of the school ) has been collected the water sample from source drinking water facilities for students and members of staff of the institutions. The water tasting report will be provide as soon as possible.

  
Signature with seal

Name- C. S. Sonwani

Designation - Sub Engineer  
PHE Sub division  
Kondagaon (C.G.)  
**Assistant Engineer**  
**Public Health Engineering**  
**Sub Division Kondagaon**

To,

DAV MUKHYAMANTRI PUBLIC SCHOOL  
BLOCK- KONDAGAON  
DISTRICT- KONDAGAON (C.G.)  
PIN CODE- 494347

**District Water Testing Laboratory**  
Public Health Engineering Department, Division - Kondagaon  
Office of The Executive Engineer  
Dongari para Kondagaon (C.G.) 494226  
(e-mail – dwtlkondagaon@gmail.com )

Test Report (Drinking Water)

Report no. DL/PHED/KGN. –	Discipline- Testing : Chemical	Group:- Drinking Water		
<b>Senders name &amp; address:-</b> Principal Dev Mukhyamantri Public School Honawandi Vishrampuri	Senders letter no./Date	02.03.2022	Sampled by	School Staff
	Sample collection date	02.03.2022	Sampling Plan & procedure	Sampling not done by Lab staff
	DL receipt no.	229	DL Receipt date	02.03.2022
	Date of analysis started	02.03.2022	Date of analysis completed	03.03.2022

Sample Details

S. N.	Sample I.D.	District /Block	City / Village	Habitation	Location/Source ID./GPS Identification
1.	229/35/03/22	Baderajpur	Vishrampuri		Dev Mukhyamantri Public School Honawandi Vishrampuri
2.					
3.					
4.					
5.					
6.					

Details of parameters their test method units and specification as per IS/APIA

S. N.	Parameters	Test method IS:3025/APIA 23rd edition			Unit	As per IS-10500-2012 Drinking Water		Result of S.No.					
		Method	Part no.	Revision & Year of Edition/ Reaffirmed		Acceptable Limit	Permissible Limit	1	2	3	4	5	6
1	2	3	4	5	6	7	8	9	10	11	12	13	14
1	pH	IS:3025	Part-11	First 1983/2017	pH scale	6.5-8.5	No relaxation	7.5					
2	Turbidity	IS:3025	Part-10	First 1984/2017	NTU	1	5	1.75					
3	Taste	IS:3025	Part-8	First 1984/2017	-	Agreeable	Agreeable	Agreeable					
4	Odour	IS:3025	Part-5	Second 2018	-	Agreeable	Agreeable	Agreeable					
5	TDS	APIA	2540-C	2017/23 <sup>rd</sup> Edt.	mg/l.	500	2000	170					
6	Colour	APIA	2120-B	2017/23 <sup>rd</sup> Edt.	Hazen	5	15	4					
7	Chloride as Cl <sup>-</sup>	IS:3025	Part-32	First 1988/2019	mg/l.	250	1000	2.99					
8	Alkalinity as CaCO <sub>3</sub>	IS:3025	Part-23	First 1986/2019	mg/l.	200	600	97.6					
9	Total Hardness as CaCO <sub>3</sub>	IS:3025	Part-21	Second 2009/2019	mg/l.	200	600	110					
10	Calcium as Ca <sup>2+</sup>	IS:3025	Part-40	First 1991/2019	mg/l.	75	200	26.4					
11	Magnesium as Mg <sup>2+</sup>	APIA 23	3500 Mg-B	2017/23 <sup>rd</sup> Edt.	mg/l.	30	100	10.6					
12	Fluoride as F <sup>-</sup>	APIA	4500-F-C	2017/23 <sup>rd</sup> Edt.	mg/l.	1.0	1.5	0.09					

- The report should not be produced partly or full without approval signatory authority of legal purpose.
- It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible" limit in the absence of alternate source in column 7 above which the sources will have to be rejected.
- The results refer only to tested samples and parameters.
- Samples will be stored for a period of 10 days from date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
- Results apply to the sample as received./ In any condition Statement of conformity not performed by lab.
- Sampling work not performed by Lab staff.

Issue no. 104/date.04/03/2022 Page..... no...../.....

*Narhari Singh*  
CHEMIST  
(Narhari Singh)  
Authorized Signatory