

**Government of Bihar
Public Health Division, Aurangabad
District Level Water Testing Laboratory
Water Quality Testing Report**

Sample submitted to lab by :- Principal D.A.V. Public School, Dayanand Bihar,
Bel. No. :- D.A.V./ABAD/2022-24/190, Dated 07.06.2023
Sample Submitted to lab on Date - 09.06.2023

SL. No.	Location of source	Type of source	Parameters tested										
			Turbidity	Conductivity	Total hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Nitrate	Fluoride	Total Coliform
1	In Campus of D.A.V. Public School Dayanand Bihar, Aurangabad Po Aurangabad-824101 School No-BR65043	Boring (Source Point)	1	896	200	46.4	20.16	28	500	0.21	1.08	2.02	-ve
Acceptable limit (IS 10500:2012)			1	-	200 mg/l	75 mg/l	30 mg/l	250 mg/l	200 mg/l	0.3 mg/l	45 mg/l	1.0 mg/l	<1.1
Maximum Permissible limit in absence of alternate source			5 NTU	-	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	1 mg/l	NR	1.5 mg/l	-

[Signature]
15.06.23
Chemist

[Signature]
15-06-23
Lab Assistant

Assistant Engineer
P.H. Sub Division Aurangabad

Executive Engineer
P.H. Division Aurangabad

[Signature]
16/6/23