

HIMACHAL PRADESH
PUBLIC WORKS DEPARTMENT

No. PWN/CB/WA/Misc Building/2020-21/5237-38 Dated:-15/12/2020
To



✓ The Principal,
D.A.V. Sr. Sec. School Bagni,
Tehsil Nurpur, Distt. Kangra (HP).

Subject: - Regarding School Building Safety Certificate.


The Inspection of the above named School was conducted by the Assistant Engineer, Sub Division, and HP.PWD. Suliali accompanied with Junior Engineer Incharge on 02.12.2020. On the basis of their inspection report, it has been found that the building has neither been designed nor constructed by this Department. No Earthquakes resistant norms have been adopted for the concerned School building. No structure drawing has been approved by the competent Govt. agency produced by the School authority. The structure is a non Engineer structure. Hence the structural safety of this building can't be ensured specially from Earthquake point of view and this building was also constructed in the year 2001. This Department will not be responsible for any type of loss of life and property etc., if this structure fails under any circumstances.

However, as per visual inspection, the building appears to be safe in appearance and accordingly the School Building Safety Certificate is being issued by this Department from 01.04.2021 to 31.03.2022. This Department could not assess the structural safety of building as the same was not constructed under the supervision of this Department.

DA/ Nil.


Executive Engineer,
Nurpur Division, HP.PWD.

Nurpur.

Copy to the Assistant Engineer, Sub Division, HP.PWD.
Suliali for information w.r.t his office letter No. 3913 dated 11.12.2020.


Executive Engineer,
Nurpur Division, HP.PWD.
Nurpur.